



Product certificate K6007/06

Issued 2020-12-01

Replaces K6007/05

Page 1 of 3

Bib-taps with integrated vacuum breaker, with or without an insert check valve

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Aalberts integrated piping systems B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K644/04 "Tapkranen, gecombineerd met beluchter, al dan niet voorzien van geïntegreerde keerklep" dated 05-12-2017.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

288171015

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company

Aalberts integrated pipingsystems B.V.
Oude Amersfoortseweg 99
1212 AA HILVERSUM
Postbus 498
1200 AL HILVERSUM
Tel. 035-6884211
www.aalberts-ips.com

Certification process
consists of initial and
regular assessment of:

- quality system
- product



Bib-taps with integrated vacuum breaker, with or without an insert check valve

Product specification

The products mentioned below belong to this certificate.

Bib-taps with vacuum breaker, without check valves:

Luxe model

050064.3 -- 1/2" without hose coupling, with Glacier knob
050065.4 -- 1/2" without hose coupling, with Premier knob
050066.5 -- 1/2" without hose coupling, with Moyen knob
056666.5 -- 1/2" without hose coupling, with Premium knob

NEN-model, head part with key operation:

050060.1 -- 1/2" with hose coupling
050061.0 -- 1/2" with hose coupling
050063.2 -- 1/2" without hose coupling

NEN-model, head part with crutch:

050040.1 -- 1/2" with hose coupling
050041.2 -- 1/2" without hose coupling
050071.1 -- 3/4" with hose coupling
050070.9 -- 3/4" without hose coupling

Bib-taps with vacuum breaker, with check valves:

Luxe model

050080.8 -- 1/2" without hose coupling, with Moyen knob
050081.9 -- 1/2" without hose coupling, with Glacier knob
050082.1 -- 1/2" without hose coupling, with Premier knob
058880.8 -- 1/2" without hose coupling, with Premium knob

NEN-model, head part with crutch:

050042.3 -- 1/2" without hose coupling
050043.4 -- 1/2" with hose coupling

NEN-model, head part with key operation:

050067.6 -- 1/2" without hose coupling

Bib-taps with integrated vacuum breaker, with or without an insert check valve

Remark

The specified products were not yet assessed for compliance with all Hygienic Aspects as inserted in the Dutch Drinking Water Decree and outlined in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Regulation materials and chemicals drinking water and warm tap water supply), implemented 19 July 2011. As soon as the final assessment policy for the products has been specified, the products shall be tested in accordance with clause 4.3.1 of the evaluation guideline.

Application and use

The bib-taps with integrated vacuum breaker, with or without an insert check valve, are designed for drinking water in installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 90 °C.

The vacuum breaker and insert check valve are designed as safety devices for the prevention of contamination of the drinking water network.

Marking

The Kiwa®-mark products are marked with the wordmark "KIWA" and/or "KK".

Place of the mark:

- "KIWA", on the body;
- KK, on the headwork.

Compulsory specifications:

- name or mark of the manufacturer, on the body and on the headwork;
- DA, on the body;
- EB, on the body, for taps provided with a check valve.

Method of marking:

- non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Aalberts integrated piping systems B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.