



Product certificate K6107/06

Issued 2022-02-01

Replaces K6107/05

Page 1 of 3

Water meter brackets

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

BEULCO GmbH & Co. KG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K645 "water meter brackets" dated 02-10-2019.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

287180711

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company
BEULCO GmbH & Co. KG
Kölner Straße 92
57439 ATTENDORN
Germany
Tel. +49 2722 695 - 0
Fax +49 2722 69 - 5240
E-mail: info@beulco.de
www.beulco.de

Certification process
consists of initial and
regular assessment of:

- quality system
- product



Water meter brackets

PRODUCT SPECIFICATION

The products mentioned below belong to this certificate

Qn 1,5, in the following models.

- model 156184 -- G $\frac{1}{2}$ " x G $\frac{1}{2}$ "
- model 156191 -- G $\frac{1}{2}$ " x G $\frac{3}{4}$ "
- model 156207 -- G $\frac{3}{4}$ " x G $\frac{3}{4}$ "
- model 262199 -- G $\frac{1}{2}$ " x G $\frac{1}{2}$ "
- model 262335 -- G $\frac{3}{4}$ " x G $\frac{3}{4}$ "
- model 262458 -- G $\frac{3}{4}$ " x G $\frac{3}{4}$ "
- model 346011 -- G $\frac{3}{4}$ " x G $\frac{1}{2}$ "
- model 357161 -- G $\frac{3}{4}$ " x G $\frac{3}{4}$ "

Qn 6, in the following models.

- model 276684 -- G1" x G1"
- model 150359 -- G1 $\frac{1}{2}$ " x G1 $\frac{1}{2}$ "
- model 156566 -- G1 $\frac{1}{2}$ " x G1 $\frac{1}{2}$ "
- model 156542 -- G1 $\frac{1}{4}$ " x G1 $\frac{1}{4}$ "
- model 264315 -- G1 $\frac{1}{4}$ " x G1 $\frac{1}{4}$ "
- model 264346 -- G1 $\frac{1}{2}$ " x G1 $\frac{1}{2}$ "
- model 276691 -- G1 $\frac{1}{4}$ " x G1 $\frac{1}{4}$ "
- model 333035 -- G1 $\frac{1}{4}$ " x G1 $\frac{1}{4}$ "

Qn 2,5, in the following models.

- model 156269 -- G1" x G1"
- model 307982 -- G $\frac{3}{4}$ " x G $\frac{3}{4}$ "
- model 156238 -- G $\frac{3}{4}$ " x G $\frac{3}{4}$ "

Qn 10, in the following models.

- model 234431 -- G1 $\frac{1}{2}$ " x G1 $\frac{1}{2}$ "
- model 234455 -- G2" x G2"
- model 264803 -- G2" x G2"

Water meter brackets

FITNESS FOR CONTACT WITH DRINKING WATER

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA ,

Place of the mark: on the bracket

Compulsory specifications:

- name or mark of manufacturer: on the bracket

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

The products are intended to install water meters according the evaluation guideline BRLK618. The water meter brackets are intended to be used in drinking water installations with a maximum water pressure of 1000 kPa and a maximum water temperature of 30°C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- BEULCO GmbH & Co. KG

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.