

Product certificate
K6163/05

Issued 2015-12-01

Replaces K6163/04

Page 1 of 2

Bib taps with integrated vacuum breaker


STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Seppelfricke Armaturen GmbH

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with

Kiwa evaluation guideline BRL-K644/03: "Bib taps, combined with vacuum breaker, with or without integrated check valve", dated 01-02-2012.



Bouke Meekma
Kiwa

Publication of the certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl



288/150609

Supplier

Seppelfricke Armaturen GmbH
Haldenstrasse 27RK1
45881 GELSENKIRCHEN
Germany
Tel. +49.2094040
Fax +49.209404496
www.seppelfricke.com

Certification process consists of initial and regular assessment of:

- quality system
- product

Bib taps with integrated vacuum breaker

PRODUCT SPECIFICATION

The products mentioned below belong to this certificate:

Bib tap with integrated vacuum breaker

no. 8001, DN 15 - with stem,
no. 8015, DN 15 - with plastic control knob (chromium).

REMARK

The above listed products were not yet assessed for compliance with all hygienic aspects as stated in the Dutch Drinking Water Decree and as outlined in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Regulation on materials and chemicals in drinking water and warm tap water supply), implemented on 19 July 2011, as specified in clause 4.3.1 of the Kiwa Evaluation guideline BRL-K644/03.

APPLICATION AND USE

Bib taps with integrated vacuum breaker are designed to be used in drinking water installations with a working pressure up to 1000 kPa and a maximum temperature of 90 °C.

The recommended limits for proper operation are a pressure between 100 and 500 kPa and a water temperature of up to 65 °C.

MARKING

The products are marked with the word mark "KIWA" and the abbreviated word mark "KK" in a rectangle.

Place of the mark:

- "KIWA": on the body;
- "KK" on the head part.

Compulsory specifications:

- manufacturer's name or mark: on the body and head part;
- "DA", to denote the integrated vacuum breaker: on the tap body;
- "EB", if a check valve is integrated: on the tap body.

Method of marking:

- non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Seppelfricke Armaturen GmbH
and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.