

Product certificate  
K6300/11

Issued 2015-12-15

Replaces K6300/10

Page 1 of 3

**Controllable backflow preventers  
Family B - Type A**

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by


**Socla SAS**

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

**Kiwa evaluation guideline BRL-K646:** "Controllable backflow preventers, family B – type A", dated 01-02-2012,

which covers the requirements of

**EN 12729: 2002:** "Devices to prevent pollution by backflow of potable water - Controllable backflow preventer with reduced pressure - Family B - Type A".



Bouke Meekma  
Kiwa

Publication of the certificate is allowed.

Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.

**Kiwa Nederland B.V.**

Sir Winston Churchillaan 273  
P.O. Box 70  
2280 AB RIJSWIJK  
The Netherlands

Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)



**Supplier**

Socla SAS  
Rue du Lt. Putier 365  
71530 VIREY-LE-GRAND  
France  
Tel. +33 3 85974200  
Fax +33 3 54700982  
[www.socla.com](http://www.socla.com)

**Certification process  
consists of initial and  
regular assessment of:**

- quality system
- product

## Controllable backflow preventers, Family B – Type A

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this certificate.

---

**BRL-K 646/03: “Controllable backflow preventer, family B - type A”.**

---

#### Backflow preventer BA 4760

DN 65 reference 3486  
DN 80 reference 3097  
DN 100 reference 3098  
DN 150 reference 3400  
DN 200 reference 3401  
DN 250 reference 3402

---

#### Backflow preventer, type BS

BA-BS006, DN 6 Acoustic group I\*  
BA-BS008, DN 8 Acoustic group I\*  
BA-BS010, DN 10 Acoustic group I\*

---

\*Acoustical category has not been re verified and is based on the previous models before 15 May 2013

---

#### Backflow preventer type BM

DN 15 reference 70.000  
DN 20 reference 70.001  
DN 25 reference 70.002  
DN 32 reference 70.003  
DN 40 reference 70.004  
DN 50 reference 70.006

### REMARK

The specified products were not yet assessed for compliance with all Hygienic Aspects as stated in the Dutch “Drinkwaterbesluit” (Drinking Water Decree) and as outlined in the “Regeling materialen en chemicaliën drink-en warm tapwatervoorziening” (Regulations for Materials and chemicals in the supply of drinking water and warm tap water), implemented on 19 July 2011, as specified in clause 4.2.1 of the Kiwa Evaluation guideline BRL-K646: d.d. 01-02-2012. .

### Controllable backflow preventers, Family B – Type A

---

#### APPLICATION AND USE

Controllable backflow preventers for both back syphonage and backpressure cross-connections combined with provision for discharge are designed as safety devices class BA for the prevention of contamination of drinking water installations having a maximum working pressure of 1000 kPA and a maximum water temperature of 65 °C.

#### MARKING

The Kiwa<sup>®</sup>-mark products are marked with the word mark "KIWA" or the abbreviated word mark "KK", in a rectangle .

Place of the mark: on the body or the specification plate.

Compulsory specifications:

- name or mark of manufacturer: on the body or the specification plate;
- indication of type: on the body or the specification plate;
- nominal size: "DN...": on the body or the specification plate;
- nominal pressure: "PN...bar": on the body or the specification plate;
- nominal temperature: "T...°C" or "...°C": on the body or the specification plate;
- an arrow showing the direction of flow: on the body.

Method of marking:

- non-erasable;
- visible after assembly.

Remark: the specification plate must bear at least the manufacturer's mark and KIWA word mark.

#### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Socla SAS
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.