



## Safety certificate K6528/12



Issued 2020-02-01  
Replaces K6528/11  
Page 1 of 3

### Combi food steamers

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### RATIONAL AG

comply with the technical specifications as laid down in this safety certificate and are marked with the Kiwa safety mark as specified in this safety certificate are, on delivery, relied upon to comply with Kiwa evaluation guideline

#### **BRL-K14011/01 “Aspects of technical water supply protection for appliances with a contamination risk”**

wherein the requirements of

#### **EN 1717: 2000 “Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow”.**

are applied for analysing the risk of contamination by backflow and for selecting the appropriate backflow prevention unit(s).

Ronald Karel  
Kiwa

Publication of the certificate is allowed.

Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.

#### **Supplier**

RATIONAL AG  
Iglinger Straße 62  
86899 LANDSBERG AM LECH  
Germany  
Tel. +49-8191327144  
Fax +49-8191327272  
[www.rational-online.com](http://www.rational-online.com)

CERTIFICATE

#### **Kiwa Nederland B.V.**

Sir Winston Churchilllaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

## Combi food steamers

### Product specification

The following types are covered by this certificate

#### Model

Oven compartment alle models

Rational CM 61, 62, 101 and 102  
 Rational CM 201 and 202  
 Rational SCC WE 61V and 101V  
 Rational SCC 61, 62, 101 and 102  
 Rational SCC 61, 62, 101 and 102, with care system  
 Rational SCC WE 61, 62, 101, 102, 202 and 201 E+G with care system  
 Rational SCC 201 and 202, with care system  
 Rational CMP 61, 62, 101, 102, 201 and 202  
 Rational CM 61G, 62G, 101G, 102G, 201G and 202G  
 Rational SCC 61G, 62G, 101G, 102G, 201G and 202G  
 Rational SCC XS 6 2/3E  
 Rational CMP XS 6 2/3E

<sup>NB1</sup> :Condenser, Control box (AB)  
<sup>NB2</sup> :Care system (AB)  
<sup>NB3</sup> :Drinking water connection point (EB)  
<sup>NB4</sup> :Hand shower (AA)  
<sup>NB5</sup> :Steam generator (AF)  
<sup>NB6</sup> : oven compartment

#### Backflow prevention unit

AB<sup>NB6</sup>  
 AB<sup>NB1</sup> & EB<sup>NB3</sup>  
 AB<sup>NB1</sup> & EB<sup>NB3</sup>  
 AB<sup>NB1</sup> & AF<sup>NB2</sup> & EB<sup>NB3</sup>  
 AB & EB  
 AB<sup>NB1</sup> & AF<sup>NB2</sup> & EB<sup>NB3</sup>  
 AB<sup>NB1</sup> & AF<sup>NB2</sup> & EB<sup>NB3</sup>  
 AB<sup>NB1</sup> & AF<sup>NB2</sup> & EB<sup>NB3</sup>  
 AB<sup>NB1</sup> & EB<sup>NB3</sup>  
 AB & EB  
 AB & EB  
 AB<sup>NB1</sup> & AA<sup>NB4</sup> & CA<sup>NB3</sup>  
 AB<sup>NB1, NB2, NB5</sup> & AA<sup>NB4</sup> & EB<sup>NB3</sup>

### LM(BR)(BZ)(X)(Y).(01)(02)(03)(04)(05)

(BR) = Type: 1 or 2 (1= with Touch/high end, 2=only Display and knobs)  
 (BZ) = project index: 00  
 (X)= Unit Size: A-G  
 A=4x2/3 trays B= 6x1 trays, C= 6x2 trays, D= 10x1 trays, E= 10x2 trays,  
 F= 20x1 trays, G= 20x2 trays  
 (Y)= Energy Type: E or G (E= Electric or Gas)

(01) = Option WLAN: A-Z\*  
 (02) = Option Power Connector: A-Z\*  
 (03) = Option Watersafety device: X  
 (04) = Option Voltage: A-Z\*  
 (05) = Option Accessories: A-Z\*

\*A-Z The various options that can be offered independently from water certification.

Condenser, Control box (AB)  
 Care system (AB)  
 Drinking water connection point (EB)  
 Hand shower (AA)  
 Steam generator (AF)

### Combi food steamers

---

#### Application and use

This certificate applies to quantity-produced “appliances with a contamination risk” intended for connection to drinking water installations. These appliances must be equipped with a backflow prevention unit at the feed in conformance with NEN 1006 that is appropriate for covering the risk of backflow of contaminating substances. The backflow prevention unit shall prevent that water upstream from the protection point will be contamination as a result of backflow from the appliances with a contamination risk and/or downstream connected applications or installation.

#### Marking

The products shall be marked with the sticker



Location of the mark:

on the outside near the water inlet connection point.

Further compulsory specifications:

- suppliers mark or logo;
- type nomination.

Method of marking:

- indelible;
- visible after mounting.

#### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- RATIONAL AG
- and, if necessary,
- Kiwa Nederland B.V.

This certificate is only valid for the technical water supply part of the product of installation. Kiwa declares herewith that the construction of this technical water supply has been conducted in such way, contamination of the drinking water installation will be prevented. Herewith Kiwa gives no statement with respect to the function or the efficiency of the under these declaration supplied products.

Consult the supplier's processing guidelines for the proper storage and transport methods.