



## Product certificate K23224/04

Issued 2021-09-01

Replaces K23224/03

Page 1 of 3

### Bib-taps with integrated vacuum breaker, with or without an insert check valve

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Raminex International B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K644 "Bib-taps with integrated vacuum breaker, with or without an insert check valve" dated 12-05-2017.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

CERTIFICATE

288180711

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

Raminex International BV  
Landzigt 34  
3454 PE Utrecht  
The Netherlands  
Tel. +31 30 241 12 24  
Fax +31 30 241 11 21  
[www.raminex.nl](http://www.raminex.nl)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Bib-taps with integrated vacuum breaker, with or without an insert check valve

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate.

Article number:	Description:
11001	bib-tap G ½ " with vacuum breaker and check valve, black control device
11002	bib-tap G ½ " with vacuum breaker and check valve, chrome plated control device
11003	bib-tap G ½ " with vacuum breaker, black control device
11004	bib-tap G ½ " with vacuum breaker, chrome plated control device
11005	bib tap G ½ "with vacuum breaker, check valve and hose connection, crank lever operated
11006	as 11005 without hose connection
11007	bib tap G ½ " with vacuum breaker, check valve and hose connection, key operated
11008	as 11007 without hose connection
11009	as 11005 without check valve
11010	as 11005 without check valve and hose connection
11011	as 11007 without check valve
11012	as 11007 without check valve and hose connection
11013	bib-tap G ¾ " with vacuum breaker, check valve and hose connection, crank lever operated
11014	as 11013 without hose connection
11015	bib tap G ¾ " with vacuum breaker, check valve and hose connection, key operated
11016	as 11015 without hose connection
11017	as 11013 without check valve
11018	as 11013 without check valve and hose connection
11019	as 11015 without check valve
11020	as 11015 without check valve and hose connection

## Bib-taps with integrated vacuum breaker, with or without an insert check valve

---



### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette). These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

The Kiwa®-mark products are marked with the wordmark "KIWA"  and/or .

Place of the mark:

- "KIWA", on the body;
- KK, on the headwork.

Compulsory specifications:

- name or mark of the manufacturer, on the body and on the headwork;
- DA, on the body;
- EB, on the body, for taps provided with a check valve.

Method of marking:

- non-erasable;
- visible after assembly.

### APPLICATION AND USE

The bib-taps with integrated vacuum breaker, with or without an insert check valve, are designed for drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 90 °C. The recommended limits are a maximum working pressure of 500 kPa and a maximum water temperature of 65 °C. The vacuum breaker and insert check valve are designed as safety devices for the prevention of contamination of the drinking water network.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Raminex International B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.