



## Product certificate K40571/05

Issued 2021-08-15

Replaces K40571/04

Page 1 of 3

# CERTIFICATE

### PE-X/Al multi-layer pipes

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### REHAU AG & Co

as specified in this product certificate and marked with the Kiwa<sup>®</sup>-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K536 E "Plastics piping systems of PE-X/Al intended for transport of hot and cold drinking water" dated 15 December 2011, inclusive amendment sheet dated 13 March 2018.

Ron Scheepers  
Kiwa

*This product certificate is only valid in combination with a Kiwa certified plastics piping system.  
Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273

Postbus 70

2280 AB RIJSWIJK

The Netherlands

Tel. +31 88 998 44 00

Fax +31 88 998 44 20

[NL.Kiwa.info@Kiwa.com](mailto:NL.Kiwa.info@Kiwa.com)

[www.kiwa.nl](http://www.kiwa.nl)

#### Company

REHAU AG Co

Eltersdorf

Ytterbium 4

91058 ERLANGEN

Germany

Tel. +49 (0)9131 / 9250

[erlangen@rehau.com](mailto:erlangen@rehau.com)

[www.rehau.com](http://www.rehau.com)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## PE-X/Al multi-layer pipes

**PRODUCT/TECHNICAL SPECIFICATION****Subject**

PE-X/Al/PE-RT multi-layer pipes

**Product characteristics**

The product complies to BRL K536-E Plastics piping systems of PE-X/Al intended for transport of hot and cold drinking water.

**Specification**

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside Diameter (mm)	Wall thickness (mm)	AL layer (mm)
16,2	2,6	0,2
20	2,9	0,3
25	3,7	0,4
32	4,7	0,4
40	6,0	0,5

Colour: inside transparent, outside white aluminium or anthracite grey.

Remarks: the joints (slide system) are made with the help of in addition supplied tools

**Fitness for contact with drinking water**

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.



The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

**MARKING**

The products shall be marked with the Kiwa-mark.

**Pipes**

The minimum required marking on the pipes shall be:

- **KIWA**  or  \* + 2/ 10 bar;
- material identification: PE-Xa;
- the buildup of the pipe; PE-X/Al/PE-RT;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clear, durable and indelible at intervals of not more than 2 meters.

\*) for smaller diameters permitted by Kiwa.

## PE-X/Al multi-layer pipes

---

### **Logistics**

Production and assembly of the system is laid down in the annex of the certification agreement.

### **APPLICATION AND USE**

The products are intended to be used for the transport of cold and hot drinking water with an operating temperature profile according to class 2 of ISO 10508 and an allowable working pressure of maximum 10 bar.

### **RECOMMENDATIONS FOR CUSTOMERS**

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- REHAU AG & Co
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.