



Product certificate K41874/03

Issued 2019-01-01

Replaces K41874/02

Page 1 of 3

Water pressure reducing valves

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Pittway Sàrl

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K14004: "Waterdruk reducerende kleppen en waterdruk reducerende combinatiekleppen"
dated 19-04-2002

which covers the requirements of

EN 1567: 1999: "Building valves - Water reducing valves and combination water pressure reducing valves – Requirements and tests"

Luc Leroy
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company
Pittway Sàrl
ACS-ECC EMEA
Z.A. La Piece 16
CH-1180 ROLLE
Switzerland
Phone +43 (0)21 695 30 00

Manufacturer
Ademco 1 GmbH
Hardhofweg
D-74821 Mosbach
Germany
Phone +49 6261 810
Fax +49 626181393
www.homecomfort.resideo.com/europe

Representative
Ademco 1 B.V.
Entrée 258
1101 EA Amsterdam Z.O.
Netherlands
Phone +31 20-5656292
Fax +31 20 2056390
<https://homecomfort.resideo.com/nl>

**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Water pressure reducing valves

Technical specification

The products mentioned below belong to this certificate

Water pressure reducing valves

D06F

adjustable outlet pressure 1,5- 6 bar

Working temperature 40°C with plastic strainer

Working temperature 70°C with brass strainer

Acoustic characteristics; group I

DN 15

DN 20

DN 25

DN 32

DN 40

DN 50

D15S

adjustable outlet pressure 1,5- 6 bar

Working temperature 30°C

DN 65

DN 80

DN 100

Application and use

This evaluation guideline specifies the requirements for water reducing valves and combination water pressure reducing valves of nominal size DN 8 to DN 100 for inlet pressures that not exceed 1.600 kPa and a temperature that does not exceed 30°C for cold water application and 80°C for hot water application

Toxicology

The specified products were not yet assessed for compliance with all aspects as inserted in the "Drinkwaterbesluit" and outlined in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" (Regulations Materials and Chemicals for Drinking Water Supplies -implemented 19 July 2011) as specified in the clause 4.2.1 of the Kiwa evaluation guideline BRL-K14004/02.

Water pressure reducing valves

Marking

The Kiwa®-mark products are marked with the word mark "KIWA".

Place of the mark: on the body or identification plate

Compulsory specifications:

- name or logo of the manufacturer;
- nominal size (DN);
- set pressure for non adjustable valves;
- an arrow for the direction of flow;
- outlet pressure for special cases;
- Dezincification resistance "DR";
- nominal pressure (maximum inlet pressure)
- maximum watertemperature;
- acoustic group classification;
- reference to EN 1567.

Method of marking:

- Non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Pittway Sàrl
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.