

Number	K44792/03	Replaces	K44792/02
Issued	2008-04-15	Dated	2007-09-15


Product Certificate  
**Water hammer arrestors**

Based on pre-certification tests as well as periodic inspections by Kiwa, the products referred to in this certificate and marked with the Kiwa-mark as indicated under 'Marking', supplied by

**Caleffi S.P.A.**

may, on delivery, be relied upon to comply with

**Kiwa evaluation guideline BRL-K632/02 : "Water hammer arrestors"**



ing. B. Meekma  
Director Certification and Inspection, Kiwa N.V.

This certificate is issued in accordance with the Kiwa-Regulations for Product Certification and consists of 3 pages.  
Publication of the certificate is allowed.

**Kiwa N.V.**  
**Certification and Inspection**  
Sir W. Churchill-laan 273  
P.O. Box 70  
2280 AB RIJSWIJK ZH  
The Netherlands

Tel. +31 70 414 44 00  
Fax +31 70 414 44 20  
E-mail [certif@kiwa.nl](mailto:certif@kiwa.nl)



**Company**  
Caleffi S.P.A.  
S.s. 2295 0  
28010 FONTANEIO  
D'AGOGNA  
Italy  
Tel. 0039 322 8491  
Fax 0039 322 863305  
E-mail [info@caleffi.it](mailto:info@caleffi.it)  
[www.caleffi.com](http://www.caleffi.com)

Page	2	Number	K44792/03	Replaces	K44792/02
		Issued	2008-04-15	Dated	2007-09-15

## Water hammer arrestor

---

### PRODUCT SPECIFICATION

#### Water hammer arrestor

Article 525130 – DN 10 – 3/8

Article 525040 – DN 15 – 1/2

Article 525150 – DN 20 – 3/4

---

### APPLICATION AND USE

Water hammer arrestors are designed to damp down pressure peaks in water pipes as part of drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 30°C.

---

### MARKING

The products are marked with the Kiwa-mark.

Place of the mark:

- on the body or identification plate.

Compulsory specifications:

- Name or logo of the manufacturer;
- Maximum operating temperature (°C);
- Denomination (DN);
- Maximum pressure;
- An arrow for the direction of flow (applicable to flow through type only).

Method of marking:

- Non-erasable;
  - Visible after installation.
- 

### RECOMMENDATIONS FOR CUSTOMERS:

1. Check at the time of delivery whether:
    - 1.1 the producer has delivery in accordance with the agreement;
    - 1.2 the mark and the marking method are correct;
    - 1.3 the products show no visible defects as a result of transport etc.
  2. If you should reject a product on the basis of the above, please contact:
    - 2.1 Caleffi S.P.A.  
and, if necessary
    - 2.2 Kiwa N.V.
  3. Consult the producer's processing guidelines for the proper storage and transport methods.
  4. Check whether this certificate is still valid by consulting [www.kiwa.nl](http://www.kiwa.nl)
-

Page

3

Number

K44792/03

Replaces

K44792/02

Issued

2008-04-15

Dated

2007-09-15