

**Product certificate**  
**K47483/03**

Issued 2015-05-01  
Replaces K47483/02  
Page 1 of 2

## Water pressure reducing valves

### STATEMENT BY KIWA


With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

## Watts Industries France

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K14004 "Water pressure reducing valves"

which covers the requirements of

**NEN-EN 1567:** "Building valves - Water pressure reducing valves and combination water pressure reducing valves - requirements and tests".



Bouke Meekma  
Kiwa

Publication of the certificate is allowed.

Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
P.O. Box 70  
2280 AB RIJSWIJK  
The Netherlands

Tel. +31 70 414 44 00  
Fax +31 70 414 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

#### Supplier

Watts Industries France  
Route Nationale 100  
80132 HAUTVILLERS-  
OUVILLE  
France  
Tel.+33 322247011  
Fax+33 322311701

[www.wattsindustries.com](http://www.wattsindustries.com)

**Certification process**  
**consists of initial and**  
**regular assessment of:**

- quality system
- product

### Water pressure reducing valves

---

#### Technical specification

The products mentioned below belong to this certificate

#### Redufix

- DN 15, adjustable
  - DN 15, non adjustable
- 

#### Application and use

Water reducing valves and combination water pressure reducing valves of nominal size DN 8 to DN 100 for inlet pressures that does not exceed 1.600 kPa and a temperature that does not exceed 30°C for cold water application and 80°C for hot water application.

#### Remark

The specified products were not yet assessed for compliance with all aspects as inserted in the "Drinkwaterbesluit" and outlined in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" (Regulations Materials and Chemicals for Drinking Water Supplies -implemented 19 July 2011) as specified in the clause 4.2.1 of the Kiwa evaluation guideline BRL-K14004/01.

#### Marking

The products are marked with the wordmark "KIWA".

Place of the mark:

- Kiwa on the body.

Compulsory specifications:

- name or logo of the manufacturer;
- nominal size (DN);
- set pressure for non adjustable valves;
- an arrow for the direction of flow;
- outlet pressure;
- Dezincification resistance "DR".

Method of marking:

- non-erasable;
- visible after installation.

#### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Watts Industries France
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.