

**technical approval-with-product
certificate
K48377/04**



Issued 2016-01-01
Replaces K48377/03
Page 1 of 3

Instaflex and IFit PB Pipes

STATEMENT BY KIWA

With this technical approval-with-product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Georg Fischer JRG AG

As specified in this technical approval-with-product certificate and marked with the Kiwa®-mark in the manner as indicated in this technical approval-with-product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K536 C "Plastics piping systems of PB intended for transport of hot and cold drinking water" dated 15-12-2011 inclusive amendment sheet 10-03-2015.

Within the framework of this technical approval-with-product certificate Kiwa does not impose any inspections with regard to the production of other parts of the plastics piping system, nor the manufacturing of the plastics piping system itself.

Luc Leroy
Kiwa

This product certificate is only valid in combination with a Kiwa certified plastics piping system.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl



285/150609

Supplier

Georg Fischer JRG AG
Hauptstrasse 130
CH-4450 SISSACH
Switzerland
Tel. (+41) 61 975 22 22
Fax (+41) 61 975 22 00

Production Location

HakaGerodur AG
Giessenstrasse 3
CH-8717 BENKEN SG
Switzerland
Tel. (+41) 55 293 25 25
Fax (+41) 55 293 25 26

**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Instaflex and IFit PB Pipes

PRODUCT SPECIFICATION

Pipes of PB according to BRL-K 536 part C: Plastics piping systems of PB intended for the transport of cold and heated drinking water.

The pipe dimensions as indicated in the table below belong to this certificate.

Table 1: Pipes of PB for Instaflex system

Nominal outside Diameter (mm)	Wall thickness (mm)	Nominal outside Diameter (mm)	Wall thickness (mm)
16	2,2	50	4,6
20	2,8	63	5,8
25	2,3	75	6,8
32	2,9	90	8,2
40	3,7	110	10,0

Table 2: Pipes of PB for iFit system

Nominal outside Diameter (mm)	Wall thickness (mm)
16	2,0
20	2,0
25	2,5
32	3,0

Colour PB pipes: Grey.

Fitness for contact with drinking water



The pipes and fittings used in this system are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette). The criteria for these hygienic aspects are recorded in the respective product certificates.

MARKING

The products are marked with the Kiwa-mark.

Pipes

The minimum required marking on the pipes shall be:

- **KIWA**  or  * + Class 2 / 10 bar;
- the manufacturer's name, trade name, system name, logo or certificate number of accompanying technical approval (system)certificate;
- material identification: PB;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

Location of the marks: on every pipe at intervals of not more than 2 m.
The realization of the marks is as follows: clear durable and indelible.

*) for smaller diameters permitted by Kiwa.

LOGISTICS

Production and assembly of the system is laid down in the annex of the certification agreement.

APPLICATION AND USE

The piping system is intended to be used for the transport of cold and hot drinking water according to a temperature profile class 2 of ISO 10508 and an allowable working pressure of maximum 10 bar.

Instaflex and IFit PB Pipes

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Georg Fischer JRG AG

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage, transport and processing methods.