



## Technical approval-with-product certificate K52317/02



Issued 2017-05-01

Replaces K52317/01

Page 1 of 3

### **PB 5-layer pipe with PB push-fit system**

#### STATEMENT BY KIWA

With this technical approval-with-product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### **NUEVA TERRAIN, S.L.**

As specified in this technical approval-with-product certificate and marked with the Kiwa®-mark in the manner as indicated in this technical approval-with-product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K536 C "Plastic Piping Systems of PB for hot and cold drinking water" dated 15-12-2011 inclusive amendment sheet dated 10-03-2015.

Within the framework of this technical approval-with-product certificate Kiwa does not impose any inspections with regard to the production of other parts of the plastics piping system, nor the manufacturing of the plastics piping system itself.

Luc Leroy  
Kiwa

285160324

*Publication of the certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### **Kiwa Nederland B.V.**

Sir Winston Churchilllaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands

Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
info@kiwa.nl  
www.kiwa.nl



#### **Certificate Holder**

NUEVA TERRAIN, S.L.  
Apartado 444  
Paduleta 2  
01195 VITORIA  
Spain  
T +34 (0)945290030  
F +34 (0)945290024



**Certification process  
consists of initial and  
regular assessment of:**

- quality system
- product

## PB 5-layer pipe with PB push-fit system

### PRODUCT SPECIFICATION

Plastics piping systems of PB intended for the transport of cold and heated drinking water according to BRL-K536 part C.

The system consists of:

- PB 5-layer pipes colour grey;
- PB mechanical fittings colour grey;
- Protection pipes.

The pipe dimensions as indicated in the table below belong to this certificate.

Nominal outside diameter in mm	Wall thickness in mm
15	1,7
22	2,0
28	2,5

### Fitness for contact with drinking water



The pipes and fittings used in this system are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette). The criteria for these hygienic aspects are recorded in the respective product certificates.

### MARKING

The products are marked with the Kiwa-mark.

#### Pipes

The minimum required marking on the pipes shall be:

- **KIWA**  or  \* + Class 2 / 8 or 10 bar;
- the manufacturer's name, trade name, system name, logo or certificate number of accompanying technical approval (system)certificate;
- material identification: PB;
- the build up of the pipe; PB/EVOH/PB;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.





Location of the marks: on every pipe at intervals of not more than 2 m.

The realization of the marks is as follows: clear durable and indelible.

\*) for smaller diameters permitted by Kiwa.

#### Fittings

The minimum required marking on the fittings shall be:

- **KIWA**  or on small products  or  or **KK** \* or **KK** \* (if not possible **KIWA**  only on the smallest packaging unit)\*\*;
- manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe in mm;
- production code.


Location of the marks: on every fitting.

The realization of the marks is as follows: clear, durable and indelible.

## PB 5-layer pipe with PB push-fit system

---

The smallest packaging unit of the fittings are provided with at least the following information:

- **KIWA** 
- manufacturer's name, trade name, system name, logo or certificate number of the accompanying technical approval (system) certificate, in accordance with the marking of the connecting pipe;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm;
- material identification in case the fitting body is made of plastics.

Location of the marks: on every package.

The realization of the marks is as follows: clear, durable and indelible.

\*) for small fittings marking with only KK is permitted

\*\*\*) only after approval by Kiwa

### Protection pipes

The minimum required marking on the protection pipes shall be:

- Kiwa (or Kiwa® word mark);
- the manufacturer's name, trade name, certificate number of the protection pipe or the certificate number of the belonging technical approval (system) certificate.

The realization of the marks is as follows: clearly and indelible at intervals of not more than 2,5 m.

### LOGISTICS

Production and assembly of the system is laid down in the annex of the certification agreement.

### APPLICATION AND USE

The piping system is intended to be used for the transport of cold and hot drinking water according to a temperature profile class 2 of ISO 10508 and an allowable working pressure of maximum 8/10 bar.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- NUEVA TERRAIN, S.L.  
and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage, transport and processing methods.