



Product certificate K55145/05

Issued 2021-06-01

Replaces K55145/04

Page 1 of 3

PE-RT/Al pipes

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Viega GmbH & Co. KG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K536 G "Plastics piping systems of PE-RT/Al intended for transport" dated 15-12-2011 inclusive amendment sheet dated 13-03-2018.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

287180711

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

Viega GmbH & Co. KG
Viega Platz 1
57439 ATTENDORN
Postfach 430/440
57428 ATTENDORN
Germany
Tel. (0) 2722 61-0
info@viega.de

Production Location

Viega Supply Chain GmbH & Co. KG
Bernrieder Straße 12
94559 Niederwinkling
Germany



Certification process
consists of initial and
regular assessment of:

- quality system
- product

PE-RT/Al pipes

TECHNICAL SPECIFICATION**Subject**

PE-RT/Al pipes

Product characteristics

The product complies to BRL K536-G Plastics piping systems of PE-RT/Al intended for transport of hot and cold drinking water.

Specification

The pipe dimensions as indicated in the table below are part of this product certificate.

PE-RT/Al Smartpress / Pexfit Pro pipes

Nominal outside diameter (mm)	Wall thickness (mm)	Wall thickness aluminum layer (mm)
16	2,0	0,2
20	2,0	0,2
20	2,3	0,2

PE-RT/Al Speedpress pipes

Nominal outside diameter (mm)	Wall thickness (mm)	Wall thickness aluminum layer (mm)
16	2,0	0,2
20	2,3	0,2
25	2,8	0,3

Colour:

PE-RT/Al PE-RT/Al Smartpress / Pexfit Pro pipes

- PE-RT/Al Smartpress / Pexfit Pro pipes inside natural; outside white;
- PE-RT/Al Speedpress pipes: inside natural; outside white;

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.


The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The products shall be marked with the Kiwa-mark.

Pipes

The minimum required marking on the pipes shall be:

- **KIWA**  and class 2 / 10 bar;
- material identification: PE-RT type 2;
- the build-up of the pipe: PE-RT/Al/PE;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clear, durable and indelible at intervals of not more than 2 meters.

PE-RT/Al pipes

Logistics

Production and assembly of the system is laid down in the annex of the certification agreement.

APPLICATION AND USE

The products are designed for drinking water installations with a lifetime of 50 years at an operating temperature profile according to class 2 of ISO 10508 and an allowable working pressure of maximum 10 bar.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Viega GmbH & Co. KG

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.