



Product certificate K61520/05

Issued 2020-08-15

Replaces K61520/04

Page 1 of 3

Bib-taps with integrated vacuum breaker, with or without an insert check valve

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

IDC Plumbing & Heating Technology (Beijing) Ltd.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K644/04 "Bib-taps with integrated vacuum breaker, with or without an insert check valve" dated 12-05-2017.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

289171015

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company

IDC Plumbing & Heating Technology (Beijing) Ltd.
3rd Floor, Unit 2, Building 2, Section A
Zhaowei Science & Technology Park, No. 14
100016 CHAOYANG DISTRICT BEIJING
P.R. China
Tel. (+86) 10.5165550
Fax (+86) 10.58220557



Certification process consists of initial and regular assessment of:

- quality system
- product

Bib-taps with integrated vacuum breaker, with or without an insert check valve

Technical specification

The products mentioned below belong to this certificate.

Bib taps with vacuum breaker, without check valve:

TYPE	DESCRIPTION
Article 544555	W/M valve with vacuum breaker and black handle (vacuum breaker POM-19030501)
Article 544556	W/M valve with vacuum breaker and chrome handle (vacuum breaker POM-19030501)

Bip taps with vacuum break, with check valve:

TYPE	DESCRIPTION
Article 544670	W/M valve with vacuum breaker, check valve and black handle (vacuum breaker POM-19030501)
Article 544554	W/M valve with vacuum breaker, check valve and chrome handle (vacuum breaker POM-19030501)

Bib-taps with integrated vacuum breaker, with or without an insert check valve

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" dated 01-07-2017 ("Materials and chemicals in the supply of drinking water and warm tap water"), published in the Government Gazette.

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.


The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed appendix hygienic aspects' to this certificate.

Application and use

The bib-taps with integrated vacuum breaker, with or without an insert check valve, are designed for drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 90 °C.

The vacuum breaker and insert check valve are designed as safety devices for the prevention of contamination of the drinking water network.

Marking

The products are marked with the wordmark "KIWA", together with the watermark logo  and/or the abbreviated word mark "KK".

Place of the mark:

- "KIWA ": on the body;
- KK: on the headwork.

Compulsory specifications:

- name or mark of the manufacturer, on the body and on the headwork; *)
- DA, on the body;
- EB, on the body, for taps provided with a check valve.

Method of marking:

- non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- IDC Plumbing & Heating Technology (Beijing) Ltd.
and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.

*) Note: adding the trademark A in addition to the compulsory specifications is admissible.