



Number	62155/02	Replaces	62155/01
Issued	15/03/2021	Scope	AR 120
Contract number	Q97/003	Page	1-2

Product Certificate

## Gasleak detector

Based on pre-certification tests as well as periodic inspections by Kiwa Nederland B.V., the products referred to in this certificate and marked with the GASTEC QA mark, supplied by

## AEROSOL SERVICE GMBH

may, on delivery, be relied upon to comply with the GASTEC QA Approval Requirements 120, for "Foam producing solution for leak detection" dated September 2019.

Ron Scheepers  
Kiwa

This certificate is issued by Kiwa Nederland B.V. in conjunction with the KIWA regulations for Certification 2017.

This certificate consists of 2 pages.  
Publication of the certificate is allowed.

Kiwa Nederland B.V.  
Sir. Winston Churchillaan 273  
P.O. Box 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel.+31 88 998 4400  
info@kiwa.nl  
www.kiwa.nl

**supplier**  
AEROSOL SERVICE GMBH  
Helmstedter Str. 58 c  
38126 Braunschweig  
Germany

<https://aerosol-service.de/>  
Mail: [info@aerosol-service.de](mailto:info@aerosol-service.de)

T +49 (0)531 / 273 82-26



Number	62155/02	Replaces	62155/01
Issued	15/03/2021	Scope	AR 120
Contract number	Q97/003	Page	2-2

## Gasleak detector

---

### PRODUCT SPECIFICATION

#### ENTRACER

Foaming gas leak detector in spray can and/or as liquid in 1 and 5 litre packaging to apply on connections in metal pipes

#### SHERLOCK

Foaming gas leak detector in spray of 150 ml and 400 ml packaging to apply on connections in metal pipes

---

### APPLICATION AND USE

Foam producing solution for leak detection for gas leaks on metal- and plastic piping systems within a temperature range of 0 °C up to and including 50 °C and an operating pressure of 20 mbar up to and including 8 bar. These approval requirements are applicable on ready-made leak detection solutions.

---

### MARKING

- GASTEC QA, GASTEC QA logo or trademark.
  - Manufacturer's or supplier's name and or registered trade mark: Griffon
  - Designation of leak detection solution
  - Essential instructions for use
  - Appropriate handling and safety labelling
  - Unique identification mark providing traceability and production date or "use by" date
- 

### RECOMMENDATIONS FOR END USERS

Check at the time of delivery whether:

- the producer has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport.

Consult the producer's processing guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting Kiwa Nederland B.V. or the Kiwa website.

If you should reject a product on the basis of the above, please contact the supplier and, if necessary, Kiwa Nederland B.V.

---