



Product certificate K67798/04

Issued 2022-08-15

Replaces K67798/03

Page 1 of 3

Inner hoses to be used for flexible connecting hoses

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Oldrati Guarnizioni Industriali Spa

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K14006 "Innerhoses to be used for flexible connecting hoses" dated 01-12-2018.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

28/11/0711

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company

Oldrati Guarnizioni Industriali Spa
Via Quarenghi 2
24060 VILLONGO
Italy
Tel. +39 035 939 213
sales3@oldrati.it
www.oldrati.it



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Inner hoses to be used for flexible connecting hoses

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate

Inner hoses

- OLDAL VMQ 880 65 TR
Material: platinum cross-linked silicone
Size: DN6, DN8, DN10, DN13 and DN15
- OLDFLEX
Material: Thermoplastic Silicone Vulcanizate (TPSiV)
Size: DN8

Inner hoses to be used for flexible connecting hoses

Fitness for contact with drinking water


This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the mark "KIWA .

Place of the mark: on the hose.

Compulsory specifications:

The hose shall be provided each 250 mm with the following marking:

- name or mark of manufacturer;
- type coding of hose;
- digits indicating the month and year of production (MM/YYYY).

Method of marking:

- indelible;
- legible.

APPLICATION AND USE

The products are intended to be used as inner hoses of flexible connecting hoses according to the Kiwa evaluation guideline BRL-K622 "Flexible connecting hoses". These flexible connecting hoses are designed for use in drinking water installations with a maximum water pressure of 1000 kPa and a maximum water temperature of 70 °C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Oldrati Guarnizioni Industriali Spa
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.