



## Product certificate K75285/04

Issued 2021-11-15

Replaces K75285/03

Page 1 of 3

### Inner hoses to be used for flexible connecting hoses

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Ningbo Newanton Rubber&Plastics products Co., LTD.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K14006 "Innerhoses to be used for flexible connecting hoses" dated 01-12-2018.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

# CERTIFICATE

286180711

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[NL.Kiwa.info@Kiwa.com](mailto:NL.Kiwa.info@Kiwa.com)  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

Ningbo Newanton Rubber&Plastics products Co., LTD.  
Liyang Road 9, Qijiashan street  
BEILUN AREA, Ningbo  
P.R. China  
Tel. +86 574-86228115  
[info@nat-rubber.cn](mailto:info@nat-rubber.cn)  
[www.nat-rubber.cn](http://www.nat-rubber.cn)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Innerhoses to be used for flexible connecting hoses

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this certificate.

#### Inner hose NAT Tubes:

<i>Article number</i>	<i>Size</i>
20200402 (small size)	6.5 x12 mm (inner diameter x outside diameter)
20200402 (big size)	15.6 x 26 mm (inner diameter x outside diameter)

## Innerhoses to be used for flexible connecting hoses

---

### **Fitness for contact with drinking water**

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### **MARKING**

The Kiwa®-mark products are marked with the wordmark "KIWA ".

Place of the mark: on the hose .

Compulsory specifications:

- manufacturer's name or mark;
- type coding of hose;
- digits indicating the month and year of production (MM/YYYY).

Method of marking:

- non-erasable;
- provided each 250 mm.

### **APPLICATION AND USE**

The inner hoses are intended to be used as part of flexible connecting hoses as meant in the Kiwa evaluation guideline BRL-K622 "Flexible connecting hoses". These flexible connecting hoses are designed for using in drinking water installations with a maximum water pressure of 1000 kPa and a maximum water temperature of 70°C.

### **RECOMMENDATIONS FOR CUSTOMERS**

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Ningbo Newanton Rubber & Plastics products Co., LTD.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.