



Product certificate K76148/05

Issued 2022-03-01

Replaces K76148/04

Page 1 of 2

Inner hoses to be used for flexible connecting hoses

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Radice Gomma di Radice Aurelio e C. S.a.s.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K14006 "Inner hoses to be used for flexible connecting hoses" dated 01-12-2018.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

286180711

Kiwa Nederland B.V.

Sir Winston Churchillaan 273

Postbus 70

2280 AB RIJSWIJK

The Netherlands

Tel. +31 88 998 44 00

Fax +31 88 998 44 20

info@kiwa.nl

www.kiwa.nl

Company

Radice Gomma di Radice Aurelio e C. S.a.s.

Via Pola 25/27

20096 PIOLTELLO (MI)

Italy

Tel. +39 02 9266135



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Inner hoses to be used for flexible connecting hoses

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate;

ECOFLEX hoses, with the following dimensions:

Nominal diameter	Inner diameter (mm)	Outer diameter (mm)	Wall thickness (mm)
DN6	6 – 7,2	9 – 10,2	1,25 – 1,6
DN8	8 – 9,2	11 – 12,4	1,25 – 1,75
DN10	9,5 – 10,5	12,7 – 14,5	1,50 – 2,00
DN13	12,0 – 13,5	16,0 – 17,5	1,75 – 2,5

Fitness for contact with drinking water

These products are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The products shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA ".

Place of the mark: on the hose.

Compulsory specifications:

- manufacturer's name or mark;
- type coding of hose;
- digits indicating the month and year of production (MM/YYYY).

Method of marking:

- non-erasable;
- legible;
- one full set of marks applied at each 250 mm (maximum) of length of hose.

APPLICATION AND USE

The products are intended to be used as inner hoses of flexible connecting hoses as meant in the Kiwa evaluation guideline BRL-K622 "Flexible connecting hoses". These flexible connecting hoses are designed for using in drinking water installations with a maximum water pressure of 1000 kPa and a maximum water temperature of 70 °C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Radice Gomma di Radice Aurelio e C. S.a.s.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.