



## Product certificate K92648/04

Issued 2022-03-01

Replaces K92648/03

Page 1 of 2

### Inner hoses to be used for flexible connecting hoses

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### POSA S.P.A.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K14006 "Inner hoses to be used for flexible connecting hoses" dated 01-12-2018.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

# CERTIFICATE

286180711

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

**Company**  
POSA S.P.A.  
Via San Francesco D'Assisi, 330  
20047 BRUGHERIO  
Italy  
Tel. +39 039 287051  
Fax +39 039 2874242  
[posa@grupposeda.it](mailto:posa@grupposeda.it)  
[www.posa.it](http://www.posa.it)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Inner hoses to be used for flexible connecting hoses

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate:

*Inner hoses starting from 6 x 9mm in the following materials:*

- Silicone Axil-76/T-MD;
- TPSiV-80/T.

### Fitness for contact with drinking water

These products are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The products shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA ".

Place of the mark: on the hose, each 250 mm:

Compulsory specifications, on the hose, each 250 mm:

- manufacturer's name or mark;
- type coding of hose;
- digits indicating the month and year of production (MM/YYYY).

Method of marking:

- non-erasable;
- visible after assembly.

### APPLICATION AND USE

The products are intended to be used as inner hoses of flexible connecting hoses according to Kiwa evaluation guideline BRL-K622: "Flexible connecting hoses". These flexible connecting hoses are designed for using in drinking-water installations with a maximum water pressure of 1000 kPa and a maximum water temperature of 70°C.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- POSA S.P.A.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.