



(Technical-approval-with-)product certificate
K95652/04

Issued 2020-07-15

Replaces K95652/03

Page 1 of 3

Legionella prevention with alternative techniques - Physical technique

STATEMENT BY KIWA

With this (technical-approval-with-)product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Aqua free GmbH

as specified in this (technical-approval-with-)product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline:

BRL-K14010 deel 1 [A1] "Legionella prevention with alternative techniques – physical technique" dated 21-03-2012.

Within the framework of this (technical-approval-with-)product certificate Kiwa does not impose any inspections with regard to the production of other parts of the (product), nor the manufacturing of the (product) itself.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

28-07-190610

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
P.O.Box 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company
Aqua free GmbH
Winsbergring 31
22525 HAMBURG
Germany
Tel. +49 40-46 89 99
<https://aqua-free.com/nl/>

Certification process
consists of initial and
regular assessment of:

- quality system
- product

Legionella prevention with alternative techniques - Physical technique

PRODUCT SPECIFICATIO

The products mentioned below belong to this technical approval-with-product certificate.

Product	Attest
AS Wall Shower	At least drafted in Dutch (and English) Instructions "AS Shower comfort"
Hand shower cBleu SCS	Booklet cBlueS 2018 RZ OHNE Stanze Pfalz
AS Shower comfort, <i>Hand shower</i>	Instructions "AS Shower comfort"
AS Shower, <i>Hand shower</i>	Instructions "AS Shower / AS Shower chrome"
AS Shower Chrome, <i>Hand shower</i>	Instructions "AS Shower / AS Shower chrome"
AS Tap, <i>Tap filter</i>	Instructions "AS Tap"
Baclyser S - 1M + 2M, <i>Membrane filter</i>	Instructions "Baclyser S"
Baclyser TR - 1M + 2M, <i>Membrane filter</i>	Instructions "Baclyser TR"
Baclyser TL - 1M + 2M, <i>Membrane filter</i>	Instructions "Baclyser TL"

Fitness for contact with drinking water

The pipes and fittings used in this system are not approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" dated 01-07-2017; ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette).

MARKING

The Kiwa[®]-mark products are marked with the word mark "KIWA"

Place of the mark: on the shower handle and replaceable element

Additional required marking:

- Manufacturer or logo;

Method of marking:

- Non-erasable;
- Visible after assembly.

Required information delivered with attest:

- Kiwa[®]-mark as shown on the right;
- Name certification holder or logo;
- Type of connection;
- Date of manufacture;
- Applied materials;
- Working pressure (PN);
- Capacity.

MF and UF filter

- Manufacturer membrane;
- Type of membrane and pore size



Legionella prevention with alternative techniques - Physical technique

APPLICATION AND USE

The physical technique is for use in collective drinking water installations and hot tap water installations with a pressure not exceeding 1 MPa (10 bar) and a temperature specified by the manufacturer. The equipment associated with the physical technique in this certificate can be installed at the following locations:

- In the line immediately before a draw-off point (point-of-use concept).

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Aqua free GmbH
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage, transport and processing methods.