



# Attest-with-product certificate K95801/01



Issued 2017-06-15

Replaces -

Page 1 of 2

## Legionella prevention with alternative techniques - Physical technique

### STATEMENT BY KIWA

With this technical approval-with-product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### SWP International Ltd

as specified in this technical approval-with-product certificate and marked with the Kiwa®-mark in the manner as indicated in this technical approval-with-product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K14010 part 1 "Legionella prevention with alternative techniques – physical technique" dated [21-03-2012].

Luc Leroy  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### Company

SWP International Ltd  
Schaperstraat 12  
B-9860 SCHELDEWINDEKE  
Belgium  
Tel. +32 (0)474-123 258

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
info@kiwa.nl  
[www.kiwa.nl](http://www.kiwa.nl)

Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Legionella prevention with alternative techniques - Physical technique

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate.

Product	Attest
<i>Model/Type:</i> <i>Hand shower: Shower-Safe SS-886</i> <i>Wall mounted: Rada Safe SS-884</i>	Installation instructions and manual  At least drafted in Dutch (and English)

### FITNESS FOR CONTACT WITH DRINKING WATER

The pipes and fittings used in this system are not fully approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette). The criteria for these hygienic aspects are recorded in the respective product certificates.

### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA", or .

Place of the mark: on filter unit, visible when in use after assembly

Required marking on packaging:

- Manufacturer or logo;
- Type of connection;
- Date of manufacture;
- Applied materials;
- Working pressure (PN);
- Capacity.

#### MF and UF filter

- Manufacturer membrane;
- Type of membrane and pore size

Method of marking:

- Non-erasable;
- visible after assembly.

### APPLICATION AND USE

The physical technique is for use in collective drinking water installations and hot tap water installations with a pressure not exceeding 1 MPa (10 bar) and a temperature specified by the manufacturer. The equipment associated with the physical technique in this certificate can be installed at the following locations:

- In the line immediately before a draw-off point (point-of-use concept).

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Safe Water Products

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage, transport and processing methods.