



Product certificate K98907/01

Issued 2018-06-01

Replaces -

Page 1 of 2

Protadur® C100

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Westfalen Gassen Nederland BV

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with BRL K15003 "Evaluation Guide for the Kiwa product certificate for products used for treatment and / or production of drinking water" dated 25-10-2016.

Luc Leroy
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company

Westfalen Gassen Nederland BV
Rigastraat 20
7418 EW DEVENTER
The Netherlands
Tel. (0)570 858420
info@westfalengassen.nl
www.westfalengassen.nl

Production Location

Productielocatie:
Westfalen CO2-Betriebgesellschaft mbH
Hans-Böckler-strasse 30
59348 LÜDINGHAUSEN
Germany



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Protadur® C100

PRODUCT SPECIFICATION

This certificate covers the product Protadur® C100, carbondioxide with a purity of > 99,9%.

PRODUCT REQUIREMENTS

The product as described in this certificate complies with BRL K15003, including the requirements as specified in NEN-EN 936.

FITNESS FOR CONTACT WITH DRINKING WATER


This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation", dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.
The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate

MARKING

Design of the required Kiwa certification mark:

- "kiwa ", in ink or seal.

Location of the mark:

- On the packaging / On the delivery receipt.

Mandatory marks:

- "kiwa ";
- "Protadur® C100";
- "K98907".

APPLICATION AND USE

Protadur® C100 (CO₂) is used in the production of drinking water for pH correction.

The maximum dosage is 25 mg CO₂ per liter drinking water.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Westfalen Gassen Nederland BV

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's (processing) guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting www.kiwa.nl.