



Product certificate K99118/01

Issued 2018-07-15

Replaces -

Page 1 of 2

Juraperle JW

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

ELT Chemicals B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL K15003 "For the Kiwa product certificate for approval of products used for treatment and or production of drinking water" dated 01-09-2017.

Luc Leroy
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

288171015

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company
ELT Chemicals B.V.
Binnenweg 10a
8475 EG NIJEHOLTPADE
The Netherlands
Tel. +31(0)561688713
info@eltchemicals.com
www.eltchemicals.com



**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Juraperle JW

PRODUCT SPECIFICATION

This certificate covers the product 'Juraperle JW', calcium carbonate with a purity of > 98%.

PRODUCT REQUIREMENTS

The product as described in this certificate complies with BRL K15003, including the requirements as specified in NEN-EN 1018.

FITNESS FOR CONTACT WITH DRINKING WATER

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation", dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.
The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate

MARKING

Design of the required Kiwa certification mark:

- "kiwa ", in ink or seal.

Location of the mark:

- On the packaging / On the delivery receipt.

Mandatory marks:

- "kiwa ";
- "Juraperle JW";
- "K99118".

APPLICATION AND USE

Juraperle JW (CaCO_3) is used in the production of drinking water for in the form of filter material.

The maximum dosage is 500 mg/l CaCO_3 per liter drinking water.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- ELT Chemicals B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.