CERTIFICATE

Product certificate
K101947/01

Issued *2019-08-01*

Replaces -

Service taps for water

STATEMENT BY KIWA
With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

OCI B.V.

as specified in this product certificate and marked with the Kiwa ®-Watermark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K611 “Service taps” 12-05-2017.

Ronald Karel
Kiwa

286/180711

Publication of this certificate is allowed.
Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company
OCI B.V.
De Hoge Brug 14
6581 AJ Malden
The Netherlands
+31(0) 24 3733833

Certification process consists of initial and regular assessment of:
- **quality system**
- **product**

Connecting valve

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate:

Service tap for water: ¾” x ¾“
Service tap for water: 1”x 1¼”

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" (“Materials and chemicals in the supply of drinking water and warm tap water Regulation” dated 01-07-2017; published in the Government Gazette).
These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- the product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed ‘appendix hygienic aspects’ to this certificate.

MARKING

The Kiwa®-Watermark products are marked with the word mark “KIWA ”.
Place of the mark: on body

Compulsory specifications:

- name or mark of the manufacturer;
- nominal size

Method of marking:

- non-erasable;
- visible after assembly.

APPLICATION AND USE

Service taps for water are intended to be used in drinking water installations with a maximum operating pressure of 1000 kPa and a water temperature of maximum 30°C. For correct functioning of the service tap, a working pressure between 100 and 500 kPa is advised.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- OCI B.V.
  and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier’s processing guidelines for the proper storage and transport methods.