



Product certificate K102547/01

Issued 2019-09-15

Replaces -

Page 1 of 3

ATLAS PP Clamp fittings

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Modern Plastics Industries LLC

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K17105 "Plastics piping systems of polyethylene for the transport of drinking water and raw water" 10-03-2017.

Ronald Karel
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

286/180711

Kiwa Nederland B.V.

Sir Winston Churchillaan 273

Postbus 70

2280 AB RIJSWIJK

The Netherlands

Tel. +31 88 998 44 00

Fax +31 88 998 44 20

info@kiwa.nl

www.kiwa.nl

Company

Modern Plastics Industries LLC

Dubai Investment Park

P.O. Box: 31550

DUBAI

United Arab Emirates

Tel. +971 (0)4 8851300

www.mpi.ae



Certification process
consists of initial and
regular assessment of:

- quality system
- product

ATLAS PP Clamp fittings

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate
Clamp fittings pressure class PN10 or PN 6 of PP for PE 80 and PE 100 pipes according to evaluation guideline BRL-K 17105 "Plastics piping systems of PE (Polyethylene) for the transport of drinking water and raw water".

The dimensions and types given in the table below are part of this product certificate.

Pipe dimensions (mm)
PN16 (20-63mm) or PN10 (75-110mm)
20
25
32
40
50
63
75
90
110

type of fittings (excluding inserts)

- Straight fitting and reducing fitting with clamp fitting end.
- Straight fitting with clamp fitting end and outside / internal thread.
- Elbow with clamp fitting end and outside/internal thread end.
- Tee and reducing Tee with clamp fitting end.
- Tee with outside/internal thread end
- End plug.

Colour: body: black
nut: black

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING


The marks and indications shall be printed or formed on the fitting and the packaging in such a way that it is durable and legible.

- Fittings shall be provided with at least the following marks:
- manufacturer's name, trade name and/or logo;
- nominal outside diameter(s) in mm of connecting pipe(s);
- Nominal pressure (PN);
- production code;
- for fittings with a support ring: nominal wall thickness of the connecting pipe;
- Type of fitting body material (only for plastic fittings).


Certification mark

After entering into the Kiwa certification agreement the word "KIWA" and the Kiwa water mark must be printed or formed on the fitting.

Kiwa water mark:



In consultation with Kiwa:

- the combination of "KIWA" and the Kiwa water mark may be replaced by:
KK of 
- may some marks be printed or formed on the (smallest) packaging unit, e.g. because the fittings are too small to be able to print or form all the marks on the fitting.

ATLAS PP Clamp fittings

APPLICATION AND USE

The products are intended to be applied in piping systems for the transport of drinking water and raw water with a maximum temperature of 40 °C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Modern Plastics Industries LLC

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.