



| | | | |
|-----------------|------------|----------|--------|
| Number | 108451/01 | Replaces | - |
| Issued | 15/05/2021 | Scope | AR 214 |
| Contract number | Q18/002 | Page | 1-2 |

Product Certificate

Polyethylene (PE) pipes for carrying gaseous fuels

Based on pre-certification tests as well as periodic inspections by Kiwa Nederland B.V., the products referred to in this certificate and marked with the GASTEC QA mark, supplied by

Dyka B.V.

may, on delivery, be relied upon to comply with the GASTEC QA approval requirements 214, for "Fitness for admixtures up to and including 100% hydrogen gas" dated June 2019.

Ron Scheepers
Kiwa

This certificate is issued by Kiwa Nederland B.V. in conjunction with the KIWA regulations for Certification 2017.

This certificate consists of 2 pages.
Publication of the certificate is allowed.

Kiwa Nederland B.V.
Sir. Winston Churchillaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands
Tel.+31 88 998 4400
info@kiwa.nl
www.kiwa.nl

supplier
Dyka B.V.
Produktieweg 7
8331 LJ Steenwijk
The Netherlands

www.dyka.nl

T +31 521 534 911



CERTIFICATE

| | | | |
|-----------------|------------|----------|--------|
| Number | 108451/01 | Replaces | - |
| Issued | 15/05/2021 | Scope | AR 214 |
| Contract number | Q18/002 | Page | 2-2 |

Polyethylene (PE) pipes for carrying gaseous fuels

PRODUCT SPECIFICATION

PE 80 pipes yellow: SDR 11 and SDR 17,6
25-50 mm. Compound code E13

PE 100 pipes black with yellow stripes: SDR 11 and SDR 17,6
63-315 mm. Compound code E15.

APPLICATION AND USE

The product is intended to be used in distribution systems for gas conform the Regulations gas quality for low caloric gas to be used up to and including 16 bar with an admixture up to and including 100% hydrogen gas. The maximum pressure and operation temperature are mentioned in the approval requirement for the product for GASTEC QA certification.

MARKING

- GASTEC QA, GASTEC QA logo or trademark.
 - Manufacturer's name and/ or trade mark;
 - Number of the system standard EN 1555;
 - For pipes $dn \leq 32$ mm; Nominal outside diameter x nominal wall thickness (dn x en);
 - For pipes $dn > 32$ mm; Nominal outside diameter, dn, SDR;
 - If applicable: type of pipe
 - Material and designation;
 - Manufacturers information: Production period, production site, material used;
 - Intended use in figures or code; word GAS.
 - The words 'Bestand tegen waterstofgas' and 'Hydrogen ready'.
-

RECOMMENDATIONS FOR END USERS

Check at the time of delivery whether:

- the producer has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport.

Consult the producer's processing guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting Kiwa Nederland B.V. or the Kiwa website.

If you should reject a product on the basis of the above, please contact the supplier and, if necessary, Kiwa Nederland B.V.
